



TOWN OF DUNDEE

RFP 22-05 ADDENDUM

2021-22 DESIGN, CONSTRUCTION, AND INSTALLATION OF A 350KW GENERATOR, INCLUDING DEMOLITION AND REMOVAL OF EXISTING GENERATOR

ADDENDUM #1

QUESTIONS FROM VENDORS

1. **Q. What is the estimated budget for RFP 22-05?**
 - A. RFP 22-05 was budgeted at \$100,000. However, Town Staff is aware that additional funds for this project may be necessary and is prepared to apply ARPA funds if necessary.
2. **Q. What is the start date for this project?**
 - A. Immediately. This project is on a tight deadline and the Town will need the awarded contractor to begin the project as soon as reasonably practicable.
3. **Q. Do you release a planholder's list?**
 - A. The Town does not release a planholder's list.
4. **Q. Can we come back out to take measurements?**
 - A. Yes, you may come out to take measurements.
5. **Q. Will be dry contacts for telemetry?**
 - A. Yes. There will be dry contacts for telemetry.
6. **Q. Will this be project be permitted?**
 - A. Yes, this project will be permitted. All permits that are required through the town will be at no cost to the contractor.
7. **Q. Does the Town have preferred subcontractors or vendors? Are there any Subcontractor restrictions?**
 - A. The Town does not have preferred subcontractors/vendors. Please see the awarded contractor's responsibility for sub-contractor in the RFP. Information on subcontractors can be found throughout the RFP, including- but not limited to- the General Provision Clauses Terms and Conditions, Sections 31, 32, 33, 35, 36, and 37.
8. **Q. Is it stated in the RFP regarding Scada? Can that be added if I ask the question?**
 - A. NO, SCADA is not in the RFP as this generator has been out of service for 5 years. You may include SCADA in your bid submission if you wish.
9. **Q. Are we installing a level two or level three for noise?**
 - A. A level tree will be required for noise.
10. **Q. The spec calls for out Enclosure: "Must be at least level 2 (weatherproof enclosure with foam powder coated steel)". However, at yesterday's pre-bid, John Vice said he would like the enclosure to be a Level III Aluminum. Please confirm?**

- A. The specs in the RFP do call for at least a level 2 enclosure. However, a level 3 would be preferred due to residential homes being near the lift station.
11. **Q. Does the Town of Dundee want to include Extreme Liner (like Rhino Liner) for the coating on the outer tank?**
- A. The Town is not opposed to extreme liner coating. You may include in your bid submission if you wish. If it is included, we encourage educational material to be included.

IMPORTANT MESSAGE:

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID COVER SHEET.